

Günther Spelsberg GmbH + Co. KG
Test- and Certification Centre

Certificate of Compliance

Certificate No.: 20405

Test Sample: WKE 1.2

Customer: AW Aroeira
Rua Orlando Gonçalves 5^a
2610-127 Amadora
Portugal

General Certificate: P-MPA-E-01-031 from 20.05.2005

MPA NRW

Requirement: E 30 to E90 according to DIN 4102-12: 1998-11

Result: The given product type WKE 1.2 is in accordance to the fire protection requirements based on this Certificate of Compliance.

Responsibility:

Günther Spelsberg GmbH + Co. KG
Test- and Certification Centre
Im Gewerbepark 1
58579 Schalksmühle / Germany

Günther Spelsberg GmbH + Co. KG

*Schalksmühle, Westfalen
D-58579 - Im Gewerbepark 1
Tel. 58574 - Postfach 15 20*

Michael Schulte

Head of Test- and Certification Centre

Schalksmühle, 16.05.2012